


## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by .... Subrata Biswas, Joint. B.O. Neturia  
 (Name of Officers with designation) from ..... B.O. Neturia .....  
 (Name of Department/ Office) inspected the Garh Panchakot International Scho  
 (Name & Address of the school) on 27-02-2024 (date of inspection) and found that  
 the Garh Panchakot International School (Name of school) has safe drinking water facilities  
 for the students and members of staff of the institution and is maintaining the hygienic sanitation  
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.  
 The above is valid for a period of ..... 01 (one) year .....

Signature with Seal: .....



Name

: SUBRATA BISWAS

Designation

: J. Block Dev. Officer  
Neturia Dev. Block

Name &amp; Address of the

: Office, B.O. Sankranti  
Dist.-Purulia (W.B.)

To

Garh Panchakot .....  
International School  
Sarbari, Neturia, Purulia, W.B.  
 (Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,  
 translated notarized version in English be uploaded along with the original vernacular certificate as a  
 single pdf.

Srabanti Das  
 School Manager  
 Garh Panchakot International School  
 PURULIA  
 Affiliation No. - 2430000



Jayanta Ghoshal  
 Principal  
 GARH PANCHAKOT INTERNATIONAL SCHOOL  
 PURULIA

Affiliation...



*Ecocare Sansol*



Phone : (0341) 2252011

Email : ecocare@sansol@rediffmail.com

Manoj Talkies Basement, Kumarpur

Asansol - 713304

Dist. Paschim Bardhaman (W.B.)

Specialised House on Environmental Monitoring, Analysis, Assessment & Management

ISO 9001:2015 Certified, OHSAS 45001:2018 Certified

ULR NO – TC51092400000508F

### TEST REPORT

Report Release Date : 18.04.2024	Sample Ref. No.(ARF) : EC/AR/29/240407
Test Report No : EC/TR/42/04008	Source of Sample : School
Type of Sample : Water	Sampling Date : 15.04.2024
Sample Collected by : Party	Period of Analysis : 16.04.2024
Sample Details : R.O Water	Sampling Location : School Compounding Area
Name & Address : Garh Panchkot International School Sarbari More P.S + P.O – Nituria Dist. Purulia Pin No. 723121 West Bengal	Sample Condition : Sealed & Preserved Sample Stamped as : ---- Sample Drawn By : Party Remarks : ---- Sampling Plan & Procedure : EC/SOP/03/01 Deviation if any : None

Sl. No.	Parameters	Unit	Test Method	Standards (IS:10500:2012)	Results
1	pH at 26.3 °C		APHA 23 <sup>rd</sup> Edition 4500-1 B	6.5 – 8.5	6.56
2	TDS	mg/l	APHA 23 <sup>rd</sup> Edition 2540 C	500 Max	30.50
3	Iron (as Fe)	mg/l	APHA 23 <sup>rd</sup> Edition 3500 – Fe B	1 Max	< 0.05

1. Test values are reported based on the samples received.
2. Sample(s) will be destroyed after 7 days from date of issues of the Test Report subject to nature of Preservation. Sample will be preserved as per the standard method.
3. The Test report shall not be reproduced, without the written approval of laboratory.

*M Pal*

Authorised Signatory

Dr. Mousumi Pal  
Ph.D.(Env.), Scientist  
Authorised Signatory

*Srabanti Das*  
School Manager  
Garh Panchkot International School  
PURULIA  
Affiliation No. - 2430390



*Jayanta Mukherjee*  
Principal  
GARH PANCHKOT INTERNATIONAL SCHOOL,  
PURULIA



*Ecocare*



Phone : (0341) 2252011

Email : ecocareasansol@rediffmail.com

Manoj Talkies Basement, Kumarpur

Asansol - 713304

Dist. Paschim Bardhaman (W.B.)

Specialised House on Environmental Monitoring, Analysis, Assessment & Management  
ISO 9001:2015 Certified, OHSAS 45001:2018 Certified

ULR NO - TC51092400000508F

### TEST REPORT

Report Release Date : 18.04.2024	Sample Ref. No./ARF : EC/ARF/29/240407
Test Repor. No : EC/TR/42/04008	Source of Sample : School
Type of Sample : Water	Sampling Date : 15.04.2024
Sample Collected by : Party	Period of Analysis : 16.04.2024
Sample Details : R.O Water	Sampling Locaton : School Compounding Area
Name & Address : Garh Panchkot International School Sarbari More P.S + P.O - Nituria Dist. Purulia Pin No. 723121 West Bengal	Sample Condition : Sealed & Preserved Sample Stamped as : ---- Sample Drawn By : Party Remarks : ---- Sampling Plan & Procedure : EC/SOP/03/01 Deviation if any : None

Sl. No.	Parameters	Unit	Test Method	Standards (IS:10500:2012)	Results
1	pH at 26.3 °C		APHA 23 <sup>rd</sup> Edition 4500-H <sup>+</sup> B	6.5 - 8.5	6.56
2	TDS	mg/l	APHA 23 <sup>rd</sup> Edition 2540 C	500 Max	30.50
3	Iron (as Fe)	mg/l	APHA 23 <sup>rd</sup> Edition 3500 - Fe B	1 Max	< 0.05

1. Test values are reported based on the samples received.
2. Sample(s) will be destroyed after 7 days from date of issues of the Test Report subject to nature of Preservation. Sample will be preserved as per the standard method.
3. The Test report shall not be reproduced, without the written approval of laboratory.

*M. Pal*

Authorised Signatory

Dr. Mousumi Pal  
Ph.D.(Env.), Scientist  
Authorised Signatory

*Srabanti Das*  
School Manager  
Garh Panchkot International School  
PURULIA  
Affiliation No. - 2430390



*Jayanta Bhattacharya*  
Principal  
GARH PANCHKOT INTERNATIONAL SCHOOL  
PURULIA